

GENERATION CAPACITY, 1990-2000
(megawatts)

<i>Year</i>	<i>Generation by System¹</i>	<i>Accumulated Installed Capacity</i>	<i>Peak Demand</i>	<i>Reserve Margin² (%)</i>
1990	TNB	4,576	3,447	32.8
	LLS	303	204	48.5
	SESCo	363	194	87.1
	Total	5,242	3,845	36.3
1995	TNB	10,111	6,276	61.1
	LLS	671	323	107.7
	SESCo	645	377	71.1
	Total	11,427	6,976	63.8
2000	TNB	13,548	10,448	29.7
	LLS	960	555	73.0
	SESCo	985	692	42.3
	Total	15,493	11,695	32.5