

**INTELLIGENT CLASSIFIER FOR INCIPIENT
PHASE FIRE IN BUILDING**

ALLAN MELVIN A/L ANDREW

**UNIVERSITI MALAYSIA PERLIS
2017**



INTELLIGENT CLASSIFIER FOR INCIPIENT PHASE FIRE IN BUILDING

by

**ALLAN MELVIN A/L ANDREW
1340611044**

A thesis submitted in fulfilment of the requirements for the degree of
Doctorate of Philosophy in Mechatronic Engineering

**School of Mechatronic Engineering
UNIVERSITI MALAYSIA PERLIS**

2017

UNIVERSITI MALAYSIA PERLIS

DECLARATION OF THESIS

Author's full name : ALLAN MELVIN A/L ANDREW
Date of birth : 1.10.1985
Title : **INTELLIGENT CLASSIFIER FOR INCIPIENT PHASE FIRE IN BUILDING**
Academic Session : 2016 - 2017

I hereby declare that the thesis becomes the property of Universiti Malaysia Perlis (UniMAP) and to be placed at the library of UniMAP. This thesis is classified as :

- CONFIDENTIAL** (Contains confidential information under the Official Secret Act 1972)*
- RESTRICTED** (Contains restricted information as specified by the organization where research was done)*
- OPEN ACCESS** I agree that my thesis is to be made immediately available as hard copy or on-line open access (full text)

I, the author, give permission to the UniMAP to reproduce this thesis in whole or in part for the purpose of research or academic exchange only (except during a period of ___ years, if so requested above).

Certified by:

SIGNATURE

SIGNATURE OF SUPERVISOR

851001-07-5713
(NEW IC NO. / PASSPORT NO.)

DATO' PROF. DR. ALI YEON MD SHAKAFF
NAME OF SUPERVISOR

Date : _____

Date : _____

ACKNOWLEDGEMENT

Throughout the fulfilment of the project, I faced a lot of challenges which gave me new experiences. I can no longer expect to be spoon-fed and must take my own initiative towards improvement and learning. Fortunately, there are some nice people who continuously supporting me in completing this project. I would not be able to successfully complete my research if not due to the help and guidance given to me by those people, in UniMAP and also outside UniMAP.

Firstly, I would like to say my deepest thank you to God for giving me strength, knowledge, wisdom and health to perform the research well.

I would like to express my sincere and profound gratitude to the Vice Chancellor of Universiti Malaysia Perlis, Yg. Bhg. Dato' Prof. Dr. Zul Azhar bin Zahid Jamal for granting me permission to study in this university.

I would like to express my thank you wishes to the Dean of School of Mechatronic Engineering, Assoc. Prof. Dr. Abu Hasan bin Abdullah for providing support during my research work.

I would like to express my heartfelt gratitude to my supervisor, Dato' Prof. Dr. Ali Yeon Md Shakaff and my co-supervisors, Prof. Dr. Abdul Hamid Adom and Dr. Ammar Zakaria for their superb guidance that spurred me on to learn more and more to gain as much knowledge as I can. They had taught me a lot of new things which are beyond my studies presently and I really appreciate their never-ending support towards me. They never say no when I approached them and it really gave me self-belief and enthusiasm to complete the studies successfully. They also provided financial support from research grants to complete this research.

Besides that, my deepest appreciation goes to the fellow researchers in Centre of Excellence for Advanced Sensor Technology (CEASTech) who are always giving me full cooperation whenever there are issues related to the project.

I would like to say also my special thank you wishes to my fiancée, Ms. Charis Solomon, my parent, relatives and friends for their encouragement and wishes which geared me up to face any obstacle in this research.

Last but not least, my sincere thank you wishes to everyone who have contributed directly or indirectly in fulfilling this study and the report. Thank you!

TABLE OF CONTENTS

DECLARATION	i
ACKNOWLEDGEMENT	ii
TABLE OF CONTENTS	iii
LIST OF TABLES	vii
LIST OF FIGURES	x
LIST OF ABBREVIATION	xiii
ABSTRAK	xvi
ABSTRACT	xvii
CHAPTER 1 INTRODUCTION	
1.1 Overview	1
1.2 Problem Statement	3
1.3 Significance of the Study	4
1.4 Scope of the Research	5
1.5 Research Objectives	8
1.6 Thesis Organization	10
CHAPTER 2 LITERATURE REVIEW	
2.1 Introduction	12
2.2 Understanding Fire	13
2.2.1 Stages of Fire	14
2.2.2 Phases of Fire Development	15
2.2.3 Heat Transfer in Buildings	17
2.2.4 Material Types in Fire	20
2.3 Automatic Fire Detection Methods	22
2.4 Types of Automatic Fire Detection Methods	25
2.4.1 Image and Video Processing Methods	27
2.4.2 Wireless Sensor Networks Methods	30
2.4.3 Statistical Methods	31
2.5 Intelligent Fire Detection Methods	33

2.5.1	Artificial Neural Networks (ANN) Methods	33
2.5.2	Fuzzy Rule- Based Methods	35
2.5.3	Hybrid Methods	37
2.6	Intelligent Learning Methods	46
2.6.1	Unsupervised Learning Networks	47
2.6.2	Supervised Learning Networks	52
2.6.3	Semi- Supervised Learning Networks	57
2.7	Commercial Fire Detection Technology Available in Market and Its Limitations	62
2.8	Summary and Research Gaps	68

CHAPTER 3 DATA COLLECTION PROTOCOL FORMATION

3.1	Introduction	71
3.2	Overall Flow Chart of Research	71
3.3	Data Measurement Devices	73
3.3.1	Indoor Air Quality (IAQ) Device	73
3.3.2	Portable Electronic Nose (PEN3)	75
3.4	Fire Test Samples	77
3.5	Experimental Testbed	78
3.5.1	Confined Space	79
3.6	Data Collection	81
3.6.1	Incipient Phase Fire Simulation using Vacuum Oven	81
3.6.2	Developing Incipient Phase Fire Material Databases	84
3.7	Precautions	86
3.8	Summary	87

CHAPTER 4 DATA PRE- PROCESSING AND MULTI- STAGE FEATURE SELECTION METHODS

4.1	Introduction	88
4.2	Data Pre- Preprocessing	88
4.3	Feature Normalisation	93
4.3.1	Relative Logarithmic Sum Squared Voltage (RLSSV)	96
4.3.2	Relative Logarithmic Voltage (RLV)	97
4.3.3	Relative Sum Squared Voltage (RSSV)	98

4.3.4	Relative Voltage (RV)	99
4.3.5	Fractional Voltage Change (FVC)	101
4.4	Feature Selection	102
4.5	Dimensional Reduction using Principal Component Analysis	107
4.6	Hybrid Features	110
4.7	Final Datasets for Analysis	113
4.8	Proposed Semi- Supervised Fire Predictor (SSFP)	116
4.8.1	Implementation of SSFP in IAQ System	122
4.8.2	Architecture of Fire Prediction System using Proposed Algorithm	125
4.9	Summary	127
CHAPTER 5 RESULTS AND DISCUSSIONS		
5.1	Introduction	128
5.2	Incipient Phase Fire Materials Classification	128
5.3	Classification using kMC Classifier	129
5.3.1	kMC Classifier for IAQ-RLSSV-8 Dataset	129
5.3.2	kMC Classifier for IAQ-RLSSV-6 Dataset	132
5.3.3	kMC Classifier for IAQ-RLSSV-4 Dataset	134
5.3.4	kMC Classifier for IAQ-RLV-8 Dataset	136
5.3.5	kMC Classifier for IAQ-RLV-6 Dataset	138
5.3.6	kMC Classifier for IAQ-RLV-4 Dataset	140
5.3.7	kMC Classifier for IAQ-FVC-8 Dataset	142
5.3.8	kMC Classifier for IAQ-FVC-6 Dataset	144
5.3.9	kMC Classifier for IAQ-FVC-4 Dataset	146
5.3.10	kMC Classifier for Proposed IAQ-Hybrid Dataset	148
5.4	Classification using PNN Classifier	150
5.4.1	PNN Classifier for IAQ-RLSSV-8 Dataset	151
5.4.2	PNN Classifier for IAQ-RLSSV-6 Dataset	151
5.4.3	PNN Classifier for IAQ-RLSSV-4 Dataset	152
5.4.4	PNN Classifier for IAQ-RLV-8 Dataset	152
5.4.5	PNN Classifier for IAQ-RLV-6 Dataset	153
5.4.6	PNN Classifier for IAQ-RLV-4 Dataset	153

5.4.7	PNN Classifier for IAQ-FVC-8 Dataset	154
5.4.8	PNN Classifier for IAQ-FVC-6 Dataset	154
5.4.9	PNN Classifier for IAQ-FVC-4 Dataset	155
5.4.10	PNN Classifier for Proposed IAQ-Hybrid Dataset	155
5.5	Classification using FkNN Classifier	156
5.5.1	FkNN Classifier for IAQ-RLSSV-8 Dataset	157
5.5.2	FkNN Classifier for IAQ-RLSSV-6 Dataset	158
5.5.3	FkNN Classifier for IAQ-RLSSV-4 Dataset	160
5.5.4	FkNN Classifier for IAQ-RLV-8 Dataset	161
5.5.5	FkNN Classifier for IAQ-RLV-6 Dataset	163
5.5.6	FkNN Classifier for IAQ-RLV-4 Dataset	164
5.5.7	FkNN Classifier for IAQ-FVC-8 Dataset	166
5.5.8	FkNN Classifier for IAQ-FVC-6 Dataset	167
5.5.9	FkNN Classifier for IAQ-FVC-4 Dataset	169
5.5.10	FkNN Classifier for Proposed IAQ-Hybrid Dataset	170
5.6	Discussion on Classification Performance of Intelligent Classifiers	172
5.7	Discussion on Implementation of Proposed SSFP Algorithm in IAQ System	182
5.8	Discussion on Behaviour of Incipient Phase Fire	190
5.9	Summary	193
 CHAPTER 6 CONCLUSION AND RECOMMENDATION		
6.1	Introduction	194
6.2	Research Findings	194
6.3	Conclusion	196
6.4	Research Contributions	197
6.5	Recommendation for Future Works	200
 References		202
List of Publications		210

LIST OF TABLES

NO		PAGE
2.1	Some of the Materials Involved in Incipient Phase Fire and the Toxic Gasses Released	20
2.2	Some Similar Works on Automatic Fire Detection (Last 10 years)	40
2.3	List of Other Key Researches on Automatic Fire Detection Methods	41
3.1	List of Gas Sensors Used in IAQ Device	74
3.2	List of Gas Sensors Used in PEN3 Device	76
3.3	Fire Test Samples in Accordance to EN54 Standard Test Fire	78
4.1	Result of Feature Selection for All Databases	106
4.2	PNN Classification Results in % for Selecting Principal Component Values in PCA for the IAQ databases	109
4.3	Latent Value Results for Selecting Principal Component Values in PCA for the IAQ databases	110
4.4	Sensitivity of Sensors Towards Fire in Fire Data Analysis	113
4.5	Sensor Elements for Each Sensor Selection Group	114
4.6	Final List of Datasets Used for Analysis in Chapter 5	115
5.1	k- Mean Clustering Classification Result for IAQ-RLSSV-8 Dataset	131
5.2	k- Mean Clustering Classification Result for IAQ-RLSSV-6 Dataset	132
5.3	k- Mean Clustering Classification Result for IAQ-RLSSV-4 Dataset	134
5.4	k- Mean Clustering Classification Result for IAQ-RLV-8 Dataset	136
5.5	k- Mean Clustering Classification Result for IAQ-RLV-6 Dataset	138
5.6	k- Mean Clustering Classification Result for IAQ-RLV-4 Dataset	140
5.7	k- Mean Clustering Classification Result for IAQ-FVC-8 Dataset	142
5.8	k- Mean Clustering Classification Result for IAQ-FVC-6 Dataset	144
5.9	k- Mean Clustering Classification Result for IAQ-FVC-4 Dataset	146
5.10	k- Mean Clustering Classification Result for IAQ-Hybrid Dataset	148

5.11	Performance of PNN for IAQ-RLSSV-8 Dataset	151
5.12	Performance of PNN for IAQ-RLSSV-6 Dataset	151
5.13	Performance of PNN for IAQ-RLSSV-4 Dataset	152
5.14	Performance of PNN for IAQ-RLV-8 Dataset	152
5.15	Performance of PNN for IAQ-RLV-6 Dataset	153
5.16	Performance of PNN for IAQ-RLV-4 Dataset	153
5.17	Performance of PNN for IAQ-FVC-8 Dataset	154
5.18	Performance of PNN for IAQ-FVC-6 Dataset	154
5.19	Performance of PNN for IAQ-FVC-4 Dataset	155
5.20	Performance of PNN for IAQ-Hybrid Dataset	155
5.21	Minimum Classification Accuracy of FkNN for IAQ-RLSSV-8 Dataset	157
5.22	Maximum Classification Accuracy of FkNN for IAQ-RLSSV-8 Dataset	157
5.23	Mean Classification Accuracy of FkNN for IAQ-RLSSV-8 Dataset	158
5.24	Minimum Classification Accuracy of FkNN for IAQ-RLSSV-6 Dataset	158
5.25	Maximum Classification Accuracy of FkNN for IAQ-RLSSV-6 Dataset	159
5.26	Mean Classification Accuracy of FkNN for IAQ-RLSSV-6 Dataset	159
5.27	Minimum Classification Accuracy of FkNN for IAQ-RLSSV-4 Dataset	160
5.28	Maximum Classification Accuracy of FkNN for IAQ-RLSSV-4 Dataset	160
5.29	Mean Classification Accuracy of FkNN for IAQ-RLSSV-4 Dataset	161
5.30	Minimum Classification Accuracy of FkNN for IAQ-RLV-8 Dataset	161
5.31	Maximum Classification Accuracy of FkNN for IAQ-RLV-8 Dataset	162
5.32	Mean Classification Accuracy of FkNN for IAQ-RLV-8 Dataset	162
5.33	Minimum Classification Accuracy of FkNN for IAQ-RLV-6 Dataset	163

5.34	Maximum Classification Accuracy of FkNN for IAQ-RLV-6 Dataset	163
5.35	Mean Classification Accuracy of FkNN for IAQ-RLV-6 Dataset	164
5.36	Minimum Classification Accuracy of FkNN for IAQ-RLV-4 Dataset	164
5.37	Maximum Classification Accuracy of FkNN for IAQ-RLV-4 Dataset	165
5.38	Mean Classification Accuracy of FkNN for IAQ-RLV-4 Dataset	165
5.39	Minimum Classification Accuracy of FkNN for IAQ-FVC-8 Dataset	166
5.40	Maximum Classification Accuracy of FkNN for IAQ-FVC-8 Dataset	166
5.41	Mean Classification Accuracy of FkNN for IAQ-FVC-8 Dataset	167
5.42	Minimum Classification Accuracy of FkNN for IAQ-FVC-6 Dataset	167
5.43	Maximum Classification Accuracy of FkNN for IAQ-FVC-6 Dataset	168
5.44	Mean Classification Accuracy of FkNN for IAQ-FVC-6 Dataset	168
5.45	Minimum Classification Accuracy of FkNN for IAQ-FVC-4 Dataset	169
5.46	Maximum Classification Accuracy of FkNN for IAQ-FVC-4 Dataset	169
5.47	Mean Classification Accuracy of FkNN for IAQ-FVC-4 Dataset	170
5.48	Minimum Classification Accuracy of FkNN for Proposed IAQ-Hybrid Dataset	170
5.49	Maximum Classification Accuracy of FkNN for Proposed IAQ-Hybrid Dataset	171
5.50	Mean Classification Accuracy of FkNN for Proposed IAQ-Hybrid Dataset	171
5.51	Result of Implementation of SSFP in IAQ System (Small Container)	183
5.52	Result of Implementation of SSFP in IAQ System (Confined Room)	187
5.53	Sensor Response Analysis for VOC Sensor for 11 Measurement Points	191
5.54	Sensor Response Analysis for NO ₂ Sensor for 11 Measurement Points	192

LIST OF FIGURES

NO		PAGE
2.1	Four Elements of Fire Tetrahedron	14
2.2	Four Stages of Fire	15
2.3	Phases of Fire Development with the Respective Phase Fire Detectors	16
2.4	Heat Transfer in Building through Conduction Process	18
2.5	Heat Transfer in Building through Convection Process	18
2.6	Heat Transfer in Building through Radiation Process	19
2.7	Fire Classification, Its Symbols and the Fire Extinguisher Chart	22
2.8	Categories in Automatic Fire Detection Researches Based on Soft Computing Techniques	26
2.9	K- Mean Clustering Result for 500 Data points and 3 Clusters	49
2.10	PNN Architecture	57
2.11	Commercial Smoke Detector	63
2.12	Commercial Heat Detector	65
2.13	Commercial Audible Warning Devices in building	66
3.1	Overall Flowchart of Research	72
3.2	IAQ Gas Sensing Array	74
3.3	IAQ System Architecture	75
3.4	Portable Electronic Nose (PEN3) from AirSense Analytics	77
3.5	Experimental Setup in the Confined Room for Data Collection (a) Vacuum Oven and Pump (b) IAQ Device at different heights (c) Position of IAQ and PEN3 Device in the Confined Room	80
3.6	Experimental Setting and the Positions of Measurement Points in Confined Space	83
3.7	Distance between Measurement Points to the Incipient Phase Fire Material Source (Top View)	83
3.8	Arrangement of IAQ Data in the Database Microsoft Excel File	85

4.1	IAQ gas sensor responses for the raw data for scorching smell generated by paper at 250°C	89
4.2	Outliers in Sensor Response	90
4.3	The Gas Sensor Responses for RLSSV Normalised Data (a) Before Outlier Removal (b) After Outlier Removal	91
4.4	Flowchart of Data Pre-processing and Proposed Multi- Stage Feature Selection Method	92
4.5	Feature Normalisation for IAQ Database	95
4.6	Group with Small Variability	103
4.7	Group with Large Variability	104
4.8	Flowchart of Feature Selection Process	106
4.9	Flowchart of Feature Dimensional Reduction using PCA, Latent Score Percentage Analysis and PNN	109
4.10	Flowchart of Feature Fusion Process to Form Proposed Hybrid Feature	111
4.11	Block Diagram of Multi- Stage Feature Selection and Feature Fusion Algorithm Used in This Chapter	112
4.12	Overall Architecture and Algorithm Used in SSFP Classifier	117
4.13	Decision Tree Diagram Used in The Proposed Algorithm, SSFP	118
4.14	Experimental Setup to Test SSFP Algorithm in IAQ System	122
4.15	Arrangement of Equipment for the Experiment	123
4.16	Custom Made Glass Container Used in the Experiment	124
4.17	Placement of the IAQ Device in the Glass Container	124
4.18	Architecture of Fire Prediction System using Proposed Algorithm	126
5.1	k- Mean Clustering of IAQ-RLSSV-8 Dataset for 10 Types of Fire Materials	130
5.2	k- Mean Clustering of IAQ-RLSSV-6 Dataset for 10 Types of Fire Materials	133
5.3	k- Mean Clustering of IAQ-RLSSV-4 Dataset for 10 Types of Fire Materials	135

5.4	k- Mean Clustering of IAQ-RLV-8 Dataset for 10 Types of Fire Materials	137
5.5	k- Mean Clustering of IAQ-RLV-6 Dataset for 10 Types of Fire Materials	139
5.6	k- Mean Clustering of IAQ-RLV-4 Dataset for 10 Types of Fire Materials	141
5.7	k- Mean Clustering of IAQ-FVC-8 Dataset for 10 Types of Fire Materials	143
5.8	k- Mean Clustering of IAQ-FVC-6 Dataset for 10 Types of Fire Materials	145
5.9	k- Mean Clustering of IAQ-FVC-4 Dataset for 10 Types of Fire Materials	147
5.10	k- Mean Clustering of IAQ-Hybrid Dataset for 10 Types of Fire Materials	149
5.11	Comparison of kMC Classification Accuracy Results for IAQ Datasets	173
5.12	Comparison of PNN Classification Accuracy Results for IAQ Datasets	175
5.13	Comparison of FkNN Classification Accuracy Results for IAQ Datasets	177
5.14	Comparison of k- Values of FkNN for IAQ Datasets	179
5.15	Comparison of Mean Classification Accuracy Results of Classifiers for IAQ Datasets	181
5.16	Correct MATLAB GUI Result for Ambient Air (Test 1)	184
5.17	Correct MATLAB GUI Result for PVC (Test 6)	185
5.18	Incorrect MATLAB GUI Result for PVC (Test 2)	186
5.19	The PVC Pipe Condition Before and After Experiment	188
5.20	The Styrofoam Condition Before and After Experiment	189
5.21	The Electrical Wire Condition Before and After Experiment	189

LIST OF ABBREVIATION

.EXE	Executable File Format
AFD	Automatic Fire Detection
ANN	Artificial Neural Network
ANOVA	Analysis of Variance
AQI	Air Quality Index
AUBE	International Conference on Automatic Fire Detection
BOMBA	Malaysian Fire and Rescue Department
BP	Back- Propagation
C	C Programming Language
CCD	Charged- Coupled Device Camera
CEASTech	Centre of Excellence for Advanced Sensor Technology
CG	Conjugate Gradient
cm	Centimetre
CO	Carbon Monoxide
CO ₂	Carbon Dioxide
DTA	Determination of Temperature Anomalies
EN54	European Standard 54
etc	Et cetera
EWFD	Early Warning Fire Detection
F _{crit}	Critical Value of F
FFA	Fuzzy Finite Automata
FkNN	Fuzzy k Nearest Neighbour Network
FTIR	Fourier Transform Infrared
FVC	Fractional Voltage Change
g	Gram
GC- MS	Gas Chromatography- Mass Spectrometer
GUI	Graphical User Interface
H ₂ O	Water
HMM	Hidden Markov Model
IAQ	Indoor Air Quality

IR	Infrared
kNN	k Nearest Neighbour
m	Metre
m ³	Metre Cube
MATLAB	MATLAB Analysis Software
ml/min	Millilitre per Minute
MLP	Multilayer Perceptron
MOX	Metal Oxide
NIST	National Institute of Standards and Technology, USA
NO ₂	Nitrogen Dioxide
O ₂	Oxygen
O ₃	Ozone
°C	Degree Celcius
PC	Principal Components
PCA	Principal Component Analysis
PEN3	Portable Electronic Nose
PLC	Programmable Logic Controller
PM ₁₀	Particulate Matter up to 10 Micron
PMF	Probability Membership Function
PNN	Probabilistic Neural Network
ppm	Parts per million
PVC	Polyvinyl Chloride
RBF	Radial Bias Function
RGB	Red, Green, Blue Colour Model
RH	Relative Humidity
RLSSV	Relative Logarithmic Sum Squared Voltage
RLV	Relative Logarithmic Voltage
RM	Ringgit Malaysia
RS232	Serial Port
RSSV	Relative Sum Squared Voltage
RV	Relative Voltage
S1	Sensor 1
Sec	Second

SI	Similarity Index
SMC	Sensor Module Cloud
SMS	Short Messaging System
SSFP	Semi Supervised Fire Predictor
SVM	Support Vector Machine
SVD	Singular Value Decomposition
T	Temperature
UAV	Unmanned Aerial Vehicle
USB	Universal Serial Bus
VOC	Volatile Organic Compounds
WinMuster	WinMuster Analysis Software
YCbCr	Luma and Chroma Colour Components

©This item is protected by original copyright

Pengelas Pintar Untuk Kebakaran Fasa Permulaan Dalam Bangunan

ABSTRAK

Pengesanan awal kebakaran adalah salah satu bidang yang mendapat perhatian dalam kajian kualiti udara dalaman. Kebolehan untuk memberikan indikasi awal kebakaran boleh membantu penghuni dalam bangunan untuk mengambil tindakan pantas untuk menghalang kebakaran tersebut. Kelewatan dalam mendapatkan indikasi sebegini bukan sahaja menyebabkan kemusnahan harta benda dan wang, tetapi ia juga menyebabkan kehilangan nyawa. Kajian ini adalah kajian di peringkat permulaan kebakaran bertujuan untuk mengesan kebakaran awal dan bahan yang terlibat (sumber api biasa dan bahan binaan bangunan) di fasa awal kebakaran menggunakan pengelas pintar. Pangkalan data *Indoor Air Quality* (IAQ) telah diwujudkan sebagai pangkalan data kajian, manakala pangkalan data *Portable Electronic Nose 3* (PEN3) diwujudkan sebagai pangkalan data untuk validasi pangkalan data IAQ. Kedua-dua pangkalan data tersebut mempunyai masukan penderia gas dari bahan kajian yang dipanaskan pada suhu berlainan dalam ruang kajian. Tujuh suhu, dari 50°C sehingga 250°C telah diuji. Untuk fasa kebakaran permulaan, data dari suhu 75°C sehingga 125°C menunjukkan keputusan yang ketara. Data tersebut telah dipraproses dan dinormalkan kepada lima jenis pencirian normal. Daripada lima jenis pencirian normal tersebut, hanya tiga jenis telah dipilih secara statistik untuk proses pemilihan ciri pelbagai peringkat dan penggabungan ciri yang dicadangkan. Sebagai hasil kepada proses yang dicadangkan tersebut, satu pencirian baru yang teguh iaitu, ciri IAQ-Hybrid telah diwujudkan. Ciri IAQ-Hybrid ini terdiri daripada komponen prinsip selepas pengurangan dimensi, digabungkan melalui teknik penggabungan ciri. Ujian ANOVA F dan Analisis Komponen Berprinsip telah digunakan untuk memilih data yang berguna dan tidak berlebihan untuk formulasi ciri yang dicadangkan. Ciri yang dicadangkan dan ciri-ciri normal lain (tiga jenis percirian normal yang telah dipilih secara statistik sebelum ini) telah diuji dengan pelbagai pengelas tanpa bimbingan, pengelas separa bimbingan dan pengelas bimbingan yang biasa digunakan. Keputusan eksperimen menunjukkan bahawa penggunaan ciri IAQ-Hybrid yang dicadangkan di dalam algoritma *Fuzzy k-Nearest Neighbour* (FkNN) telah memberikan ketepatan klasifikasi purata sebanyak 96.15% yang lebih baik berbanding kaedah penormalan ciri konvensional lain di dalam pengelas berbeza (82.26% sehingga 92.80%). Berdasarkan keputusan ketepatan klasifikasi, ciri dan pengelas terbaik telah dipilih untuk digunakan di dalam Penjangka Kebakaran Separa Bimbingan (SSFP) yang dicadangkan. Algoritma SSFP yang dicadangkan merangkumi dua bahagian. Bahagian pertama adalah pengesanan kebakaran fasa permulaan menggunakan indeks persamaan berdasarkan peraturan di dalam algoritma *Decision Tree* manakala bahagian kedua adalah pengelasan bahan kebakaran menggunakan ciri IAQ-Hybrid dan algoritma FkNN yang dipilih sebelum ini. Algoritma SSFP yang dicadangkan telah dilaksanakan dan diuji di dalam sistem IAQ. Pelaksanaan algoritma yang dicadangkan di dalam sistem IAQ ternyata berjaya. Kadar kejayaan pengesanan kebakaran dan klasifikasi bahan adalah 100% dan 83.33% masing-masing. Keputusan ujian menunjukkan bahawa semua kejadian kebakaran fasa permulaan telah dikesan dengan betul, walaupun terdapat dua kejadian di mana kesalahan klasifikasi telah berlaku untuk klasifikasi bahan kebakaran. Kaedah untuk penambahbaikan situasi ini telah dimasukkan dalam bahagian kesimpulan tesis ini.

Intelligent Classifier for Incipient Phase Fire in Building

ABSTRACT

Early fire detection is one of the most promising sub- fields in indoor air quality research. Ability to give early fire indication can help the building occupants to take responsive actions in order to prevent the fire. Delay in having such indication not only leading to property and money losses, but also life losses. This research is a preliminary research intended to detect the early fire and the material (common fire sources and building construction materials) involved in the fire using intelligent classifier. Indoor Air Quality (IAQ) database is formed as the testing database, while Portable Electronic Nose 3 (PEN3) database is formed to verify the IAQ database. The databases consist of gas sensor inputs from the test materials, heated up at different temperatures in the testbed. Seven temperatures, range from 50°C up to 250°C have been tested. For incipient phase fire, data for temperature range 75°C up to 125°C shows a very significant result. The data is pre-processed and normalised into five types of normalised features. Out of the five normalised features, only three were statistically selected for proposed multi- stage feature selection and feature fusion process. As an output to the proposed process, a new robust feature, IAQ-Hybrid feature is formed. IAQ-Hybrid feature is consisting of dimensionally reduced principal components fused by the feature fusion technique. ANOVA F- Test and Principal Component Analysis are used for selecting the useful and non- redundant data for the proposed feature formulation. The proposed feature and the other normalised features (three types of normalised features which were statistically selected earlier) are tested with various common unsupervised, semi- supervised and supervised classifiers. Experimental results show that the use of proposed IAQ-Hybrid feature in Fuzzy k- Nearest Neighbour (FkNN) algorithm yields a better mean classification accuracy of 96.15% compared to the conventional feature normalisation methods in other classifiers (82.26% to 92.80%). Based on the classification performance result, the best feature and the best classifier are selected to be implemented in the proposed Semi- Supervised Fire Predictor (SSFP). The proposed SSFP algorithm comprises of two parts. The first part is incipient phase fire detection using rule- based similarity index in Decision Tree algorithm, while the second part is the fire material classification using the previously selected IAQ-Hybrid feature and FkNN algorithm. The proposed SSFP algorithm is implemented and tested in the IAQ system. The implementation of the proposed algorithm in IAQ system is proven successful. The success rates of fire detection stage and material classification stage are 100% and 83.33% respectively. The test result shows that all events of incipient fire are correctly detected, although there were two incidents of misclassification happened for fire material classification. The measures to improve this situation are given in the conclusion of this thesis.

CHAPTER 1

INTRODUCTION

1.1 Overview

Fire handling is crucial for the development of human civilisation. Fire is considered one of the main causes for lives and property losses among different types of disasters.

Having proper control over it is extremely important to overcome the worrying statistics of total fire cases reported. According to the latest data from Fire Safety and Rescue Department (BOMBA) of Malaysia's Annual Report, in 2014 alone, there were 54540 fire cases reported (Fire and Rescue Department, Malaysia, 2014). Out of the stated 54540 cases, 16039 cases happened in the buildings or closed spaces. 5677 cases happened due to the building and its contents, 130 cases happened due to the failures in machines, 1429 cases happened due to tools and utilities, 6 cases happened due to chemical substances, 549 cases happened due to gases, and the remaining 8248 cases happened due to the other causes. Most of the fire cases happened in residential buildings, shops, factories, storage facilities, institutional buildings, offices, gathering places and other types of buildings.

The assessment of property losses carried out by BOMBA indicated that fire outbreaks directly contributed towards property damages of approximately RM7.483 billion over a five-year period (Fire and Rescue Department, Malaysia, 2014). In the year 2014, RM2.8 billion worth of property was damaged in in- building fire. Looking closely, there was an exponential rise in the worth of damages, starting from RM756 million in year 2010 up to RM2.8 billion in 2014.

In the like manner, the number of effected fire victims is at a critical concern level, with 1347 casualties reported over the last five-year period (year 2010 - 2014). In year 2010, an alerting 171 deaths was recorded and a total number of 161, 250, 237 and 528 death cases were respectively numbered from year 2011 to year 2014. Moreover, year 2014 recorded a drastic increase in the number of fire victim, doubling the statistics of cases recorded in year 2013 (Fire and Rescue Department, Malaysia, 2014). Sadly, almost all the cases could have been avoided if pre- warning concerning the fire had been given to the occupants in the building (Anderson & Ezekoye, 2013).

As of present, various parties, in numerous ways, have intervened to curb the escalating building fire hazards. Intervention from the fire safety and rescue department, the insurance agencies, stricter building safety rules and regulations, prevention measures and education, improvisation in the materials and goods used in the building, and the inventiveness of the building to have a better resistance to the fire, have helped in easing the losses suffered in the in- building fire (Anderson & Ezekoye, 2013). Although all these interventions and improvisations have helped to reduce the effect of post- fire damages, they are not sufficient and in most cases, not helpful for early fire prediction and prevention. The negligence of society to focus on early fire identification can be costly in this modern era, especially with sophisticated, complex and costly technologies involved in our daily life (Anderson & Ezekoye, 2013).

Over the last decade, researches on early fire sensing, especially systems involving an array of gas sensors and improved detection algorithms, has drawn significant attention from both researchers and engineers. Narrowing down to this research, this research work aims to enhance the existing indoor air quality system with an added fire detection capability and fire material prediction. In accordance to that, various intelligent methods are tested and the optimum classifier is suggested. Assorted

gas sensing and artificial intelligence have been utilised. Moreover, the features extracted from the fire test samples are utilised to develop the classification models. The proposed models are then trained and tested for implementation. The models are designed to suit the building structures in Malaysia. The main motivation and objectives of this research work has been discussed in this chapter.

1.2 Problem Statement

Existing fire alarms have limited capability to detect fire at an early phase. The limited and improper sensors in the fire detection system could lead to further harms, this is because, the alarming system is only activated when higher smoke density or temperature is detected. Therefore, the chances of the system creating false fire alarm is high. On the other end, having an effective fire alarm with advanced detection algorithms are proven to be expensive. These are some of the reasons why most shop lot and office owners in Malaysia neglect the significance of a proper fire sensing alarms in their premises. To overcome this situation, many fire detection systems were proposed by past researchers and fire safety devices manufacturers, but not all are capable at performing early fire prediction and detection. In the market, most of the systems are incorporated with computationally complex algorithms, and thus, are highly priced. Therefore, it is clear that a practical solution should be identified to best resolve this problem. Thus, this research aims to find the optimal algorithm to predict the event of fire more precisely and faster which can be easily incorporated in the current air quality monitoring device. The proposed algorithm will detect fire at an early stage from the smell of scorching materials and latter predict the burning material efficiently.

1.3 Significance of the Study

This research work will be helpful for Malaysians in various ways. The primary advantage is to help the building occupants in a case of fire by giving reliable indication that fire is about to start in the building. The scorching smell of fire is the earliest indication of fire and at this phase, there will be no visible sign of smoke been generated. Having an intelligent system to detect the fire at the earliest possible stage will help the occupants to evaluate the situation and to take the necessary actions in safeguarding themselves and their properties. The algorithm in the proposed system will continuously check for the fire signatures from the indoor air quality and alarm the system when any fire pattern is detected. The common fire patterns were pre-trained in the system. The system will intelligently compare the current reading to the pre-trained reading. The algorithm is designed and tested in such a way that it can be used in any local buildings pervasively. Therefore, it will indirectly reduce the fire cases in Malaysia as well as help in saving valuable lives and properties. Another advantage of the proposed system would be, in terms of the fire material prediction. The proposed system has the capability to identify types of materials involved in the fire. Ten material samples “smellprint” which consisted of various commonly available fire sources and building construction materials have been trained in the system. Once the fire is detected, the smell will be analysed for similarity of pre-trained smell. When the particular smell matches one of the trained material “smellprint”, the end user will be alerted. This information is extremely useful, especially to the firefighters to use suitable or fitting fire extinguisher to put out the fire. This is because, the use of incorrect fire extinguisher can cause fire to spread to the other parts of the building. For example, in the case of fire involving oil, where the panicked occupants may tend to use water in the effort to put it out. Next, in the case of fire involving a blend of materials or

unknown materials, the proposed classifier will choose the dominant group or include it under “Unknown Material” group. Thus, having this feature is useful. In addition, the technology used in this system has its own advantages. Such as, the utilisation of an improved array of sensors or better known as electronic nose provides better detection and prediction of fire. Looking at commercial systems, the limited number of sensor is rather inconvenient for life- threatening situations like a fire breakout because it requires faster responses to solve it. Contrarily, the use of electronic nose in fire detection is considered a perfect solution since sniffing is the primary way humans detects the event of fire. Therefore, an electronic nose is used in this system. Other technologies such as wireless data collection and monitoring features can be installed in this system also to ensures the expandability of the system. The proposed system is easy to be installed and functions as a user- friendly assistant to anyone, with or without any experience in handling technology stuffs.

1.4 Scope of the Research

This research work is a preliminary work in detecting incipient phase fire in building using Indoor Air Quality (IAQ) device. IAQ device was developed and deployed in Centre of Excellence for Advanced Sensor Technology (CEASTech) lab. The main function of the IAQ device is to evaluate the indoor air quality using the Air Quality Index (AQI). Although the primary aim of the IAQ device is to calculate the AQI of the area, its function can be further expanded by introducing new features into it. One of the feature that can be included is the fire detection capability. Since the IAQ device is using an array of eight metal oxide and electrochemical gas sensors in its design, it is easier to be incorporated for fire detection application since the main